

Compliance Statement

No. 2025-646

Screened Channel, Class E_A

Company

Bimel Elektronik Mam. Paz. A.S.
Anadolu Bulv. No:20 Timko N Blok/8 Yenimahalle
06420 Ankara
TURKEY

Channel Identification (4 connector model)

Horizontal cable:

Beek Cat7 S/FTP Horizontal LSOH Cable
Part no. BC-XXX-SF7-HF (XXX coding for length)

RJ45 connector for telecommunications outlet, consolidation point, and patch panel:

Beek Cat6A shielded Toolless Keystone
Part no. BN-KJ6A-S1

Terminal cord, patch cord:

Beek Cat6A S/FTP LSOH Patch Cord
Part no. BC-S6AXXXY (XXX coding for length, Y coding for colour)

Consolidation point cord, equipment cord:

Beek Cat6A S/FTP LSOH Cons. P. Cord
- with jack BN-KJ6A-S1 added
Part no. BC-S6AXXXY-CP (XXX coding for length, Y coding for colour)

Generic cabling standards - Class E_A Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-E:2024

Technical report

12532292-02, DANAK-19/25333

EC Cabling product ID

7295

CS valid until


1 December 2026

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 1 December 2025



Nis Jepsen
Specialist, Project Manager



Lars Lindskov Pedersen
Senior Team Leader, Test Manager

